

VOC Content Test Certificate

Thursday 27th May 2021

Supplier: Resene Construction Systems (5 Venture Place, Middelton, Christchurch, 8024, New Zealand).

Sample Description: ROCKCOTE Marblestone Interior Plaster

Date Tested: May 2021 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960-05 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960 as detailed for paints as well as South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:


Specification NZGBC – Green Star and Homestar Tools V4.1	ROCKCOTE Marblestone Interior Plaster
Multipurpose Construction Adhesive Limit: ≤ 70 grams per liter	502 grams per Litre as VOC content per material
Meets NZGBC VOC Content Requirement	No



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Dr. Tuan Duong
PhD, BE (Chem. Eng.)
Senior Consultant



Srikanth C Srivatsa
PhD (Chemistry)
Consultant

V2105041