

# VOC Content Test Certificate

Thursday 27<sup>th</sup> May 2021

Supplier: Resene Construction Systems (5 Venture Place, Middelton, Christchurch, 8024, New Zealand).

Sample Description: ROCKCOTE Venetian Interior Plaster

Date Tested: May 2021 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960-05 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960 as detailed for paints as well as South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:


<b>Specification</b> NZGBC – Green Star and Homestar Tools V4.1	<b>ROCKCOTE Venetian Interior Plaster</b>
<b>Multipurpose Construction Adhesive Limit:</b> ≤ 70 grams per liter	<b>1 grams per Litre as VOC content per material</b>
<b>Meets NZGBC VOC Content Requirement</b>	<b>Yes</b>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Dr. Tuan Duong  
PhD, BE (Chem. Eng.)  
Senior Consultant



Srikanth C Srivatsa  
PhD (Chemistry)  
Consultant

V2105041