

Sheet List Table		
Sheet Number	Sheet Title	Sheet Revision Date
39.00.00	Drawing Register - Firewall 120 mins	
39.18.00	Foundation - Firewall 120 mins	1 November 2017
39.18.01	Fascia - Firewall 120 mins	1 November 2017
39.18.02	External Corner - Firewall 120 mins	1 November 2017
39.18.05	Vertical Control Joint (Fire Break) 120 mins	1 November 2017
39.18.06	Vertical Control Joint (T-Intersection W Conc Block)	1 November 2017
39.18.07	Internal Corner (T-Section W Conc Block)	1 November 2017
39.18.50	2 Way Firewall Cross Section - 120FRR	1 November 2017
39.18.90	120 Minute Firewall Information	1 November 2017

TradeSpec™ and RenderSpec™ are Registered Trademarks, both Documents are available on the Resene Construction Systems



CONFIDENTIALITY: No part of this publication may be reproduced or transmitted other than the intended use by Resene Construction Systems without written consent from the author.

System
Integra Construction Systems


Substrate
120 Minute Firewall

Drawing Name
Drawing Register - Firewall 120 mins

Scale
1 : 2 @ A4

Date
29 July 2024

Sheet
39.00.00



FRR 120/120/120

- 90x45 framing at 400mm centres
- 140x45 framing at 600 centres
- 2400mm stud height
- 50mm Integra Panel
- 2 16mm GIB Fyrelite® one side fixed to GBTL 120
- Timber framing as per section 6.3
- Full Render System with Mineral Texture and Resene Lumbersider



The external walls are required to be fire rated depending upon the situation when the wall is close to a boundary or a neighbouring property in order to comply with NZBC clause C3. The walls included in this section are load bearing walls as per NZS 3604. Special attention must be paid to junctions and penetrations in external walls. The external claddings may be required to be fixed over a cavity and the cavity must not open into the roof space or sub floor space.

For buildings within the scope of NZS 3604 the bottom plates for all fire rated walls must be supported and fixed to floors using a Pryda Brace Anchor fixed with Ramset 'Anka Screw' M12 x 150mm or proprietary fasteners as per Section 7.5.12. of NZS 3604. For the Specific Engineering Design projects (SED), it is the structural engineer/designer's responsibility to ensure that the floor and wall connections are designed/ constructed to withstand the emergency loading requirements expected as per Clause B1 of NZBC.

TradeSpec™ and RenderSpec™ are Registered Trademarks, both Documents are available on the Resene Construction Systems

Resene 
Construction Systems

CONFIDENTIALITY: No part of this publication may be reproduced or transmitted other than the intended use by Resene Construction Systems without written consent from the author.

System
 Integra Construction Systems


Substrate
 120 Minute Firewall

Drawing Name
 Foundation - Firewall 120 mins

Scale
 1 : 2 @ A4

Date
 1 November 2017

Sheet
 39.18.00



The external walls are required to be fire rated depending upon the situation when the wall is close to a boundary or a neighbouring property in order to comply with NZBC clause C3. The walls included in this section are load bearing walls as per NZS 3604. Special attention must be paid to junctions and penetrations in external walls. The external claddings may be required to be fixed over a cavity and the cavity must not open into the roof space or sub floor space.

For buildings within the scope of NZS 3604 the bottom plates for all fire rated walls must be supported and fixed to floors using a Pryda Brace Anchor fixed with Ramset 'Anka Screw' M12 x 150mm or proprietary fasteners as per Section 7.5.12. of NZS 3604. For the Specific Engineering Design projects (SED), it is the structural engineer/designer's responsibility to ensure that the floor and wall connections are designed/ constructed to withstand the emergency loading requirements expected as per Clause B1 of NZBC.

TradeSpec™ and RenderSpec™ are Registered Trademarks, both Documents are available on the Resene Construction Systems

Resene 
Construction Systems

CONFIDENTIALITY: No part of this publication may be reproduced or transmitted other than the intended use by Resene Construction Systems without written consent from the author.

System
 Integra Construction Systems


Substrate
 120 Minute Firewall

Drawing Name
 Fascia - Firewall 120 mins

Scale
 1 : 2 @ A4

Date
 2 June 2019

Sheet
 39.18.01



The external walls are required to be fire rated depending upon the situation when the wall is close to a boundary or a neighbouring property in order to comply with NZBC clause C3. The walls included in this section are load bearing walls as per NZS 3604. Special attention must be paid to junctions and penetrations in external walls. The external claddings may be required to be fixed over a cavity and the cavity must not open into the roof space or sub floor space.

For buildings within the scope of NZS 3604 the bottom plates for all fire rated walls must be supported and fixed to floors using a Pryda Brace Anchor fixed with Ramset 'Anka Screw' M12 x 150mm or proprietary fasteners as per Section 7.5.12. of NZS 3604. For the Specific Engineering Design projects (SED), it is the structural engineer/designer's responsibility to ensure that the floor and wall connections are designed/ constructed to withstand the emergency loading requirements expected as per Clause B1 of NZBC.

TradeSpec™ and RenderSpec™ are Registered Trademarks, both Documents are available on the Resene Construction Systems

Resene 
Construction Systems

CONFIDENTIALITY: No part of this publication may be reproduced or transmitted other than the intended use by Resene Construction Systems without written consent from the author.

System
 Integra Construction Systems


Substrate
 120 Minute Firewall

Drawing Name
 External Corner - Firewall 120 mins

Scale
 1 : 2 @ A4

Date
 1 November 2017

Sheet
 39.18.02



FRR 120/120/120

- 90x45 framing at 400mm centres
- 140x45 framing at 600 centres
- 2400mm stud height
- 50mm Integra Panel
- 2 16mm GIB Fyrelite® one side fixed to GBTL 120
- Timber framing as per section 6.3
- Full Render System with Mineral Texture and Resene Lumbersider



All Control Joint spacings and setouts are the responsibility of the Designer, for suggested locations refer to RCS TradeSpec™ Document 1.4

Ensure that a horizontal batten is used to form a horizontal fire break between the vertical fire breaks where the wall meets the soffit/fascia/drainage joint



The external walls are required to be fire rated depending upon the situation when the wall is close to a boundary or a neighbouring property in order to comply with NZBC clause C3. The walls included in this section are load bearing walls as per NZS 3604. Special attention must be paid to junctions and penetrations in external walls. The external claddings may be required to be fixed over a cavity and the cavity must not open into the roof space or sub floor space.

For buildings within the scope of NZS 3604 the bottom plates for all fire rated walls must be supported and fixed to floors using a Pryda Brace Anchor fixed with Ramset 'Anka Screw' M12 x 150mm or proprietary fasteners as per Section 7.5.12. of NZS 3604. For the Specific Engineering Design projects (SED), it is the structural engineer/designer's responsibility to ensure that the floor and wall connections are designed/ constructed to withstand the emergency loading requirements expected as per Clause B1 of NZBC.

TradeSpec™ and RenderSpec™ are Registered Trademarks, both Documents are available on the Resene Construction Systems

Resene 
Construction Systems

CONFIDENTIALITY: No part of this publication may be reproduced or transmitted other than the intended use by Resene Construction Systems without written consent from the author.

System
Integra Construction Systems


Substrate
120 Minute Firewall

Drawing Name
Vertical Control Joint (Fire Break) 120 mins

Scale
1 : 2 @ A4

Date
1 November 2017

Sheet
39.18.05



FRR 120/120/120

- 90x45 framing at 400mm centres
- 140x45 framing at 600 centres
- 2400mm stud height
- 50mm Integra Panel
- 2 16mm GIB Fyrelite® one side fixed to GBTL 120
- Timber framing as per section 6.3
- Full Render System with Mineral Texture and Resene Lumbersider

The external walls are required to be fire rated depending upon the situation when the wall is close to a boundary or a neighbouring property in order to comply with NZBC clause C3. The walls included in this section are load bearing walls as per NZS 3604. Special attention must be paid to junctions and penetrations in external walls. The external claddings may be required to be fixed over a cavity and the cavity must not open into the roof space or sub floor space.



For buildings within the scope of NZS 3604 the bottom plates for all fire rated walls must be supported and fixed to floors using a Pryda Brace Anchor fixed with Ramset 'Anka Screw' M12 x 150mm or proprietary fasteners as per Section 7.5.12. of NZS 3604. For the Specific Engineering Design projects (SED), it is the structural engineer/designer's responsibility to ensure that the floor and wall connections are designed/ constructed to withstand the emergency loading requirements expected as per Clause B1 of NZBC.

TradeSpec™ and RenderSpec™ are Registered Trademarks, both Documents are available on the Resene Construction Systems

Resene 
Construction Systems

CONFIDENTIALITY: No part of this publication may be reproduced or transmitted other than the intended use by Resene Construction Systems without written consent from the author.

System
 Integra Construction Systems


Substrate
 120 Minute Firewall

Drawing Name
 Vertical Control Joint (T-Intersection W Conc Block)

Scale
 1 : 2 @ A4

Date
 1 November 2017

Sheet
 39.18.06



The external walls are required to be fire rated depending upon the situation when the wall is close to a boundary or a neighbouring property in order to comply with NZBC clause C3. The walls included in this section are load bearing walls as per NZS 3604. Special attention must be paid to junctions and penetrations in external walls. The external claddings may be required to be fixed over a cavity and the cavity must not open into the roof space or sub floor space.

For buildings within the scope of NZS 3604 the bottom plates for all fire rated walls must be supported and fixed to floors using a Pryda Brace Anchor fixed with Ramset 'Anka Screw' M12 x 150mm or proprietary fasteners as per Section 7.5.12. of NZS 3604. For the Specific Engineering Design projects (SED), it is the structural engineer/designer's responsibility to ensure that the floor and wall connections are designed/ constructed to withstand the emergency loading requirements expected as per Clause B1 of NZBC.

TradeSpec™ and RenderSpec™ are Registered Trademarks, both Documents are available on the Resene Construction Systems

Resene 
Construction Systems

CONFIDENTIALITY: No part of this publication may be reproduced or transmitted other than the intended use by Resene Construction Systems without written consent from the author.

System
 Integra Construction Systems


Substrate
 120 Minute Firewall

Drawing Name
 Internal Corner (T-Section W Conc Block)

Scale
 1 : 2 @ A4

Date
 1 November 2017

Sheet
 39.18.07



FRR 120/120/120

- 90x45 framing at 400mm centres
- 140x45 framing at 600 centres
- 2400mm stud height
- 50mm Integra Panel
- 2 16mm GIB Fyrelite® one side fixed to GBTL 120
- Timber framing as per section 6.3
- Full Render System with Mineral Texture and Resene Lumbersider



The external walls are required to be fire rated depending upon the situation when the wall is close to a boundary or a neighbouring property in order to comply with NZBC clause C3. The walls included in this section are load bearing walls as per NZS 3604. Special attention must be paid to junctions and penetrations in external walls. The external claddings may be required to be fixed over a cavity and the cavity must not open into the roof space or sub floor space.

For buildings within the scope of NZS 3604 the bottom plates for all fire rated walls must be supported and fixed to floors using a Pryda Brace Anchor fixed with Ramset 'Anka Screw' M12 x 150mm or proprietary fasteners as per Section 7.5.12. of NZS 3604. For the Specific Engineering Design projects (SED), it is the structural engineer/designer's responsibility to ensure that the floor and wall connections are designed/ constructed to withstand the emergency loading requirements expected as per Clause B1 of NZBC.

TradeSpec™ and RenderSpec™ are Registered Trademarks, both Documents are available on the Resene Construction Systems

Resene 
Construction Systems

CONFIDENTIALITY: No part of this publication may be reproduced or transmitted other than the intended use by Resene Construction Systems without written consent from the author.

System
 Integra Construction Systems

Substrate
 120 Minute Firewall


Drawing Name
 2 Way Firewall Cross Section - 120FRR

Scale
 1 : 2 @ A4

Date
 1 November 2017

Sheet
 39.18.50

INTL120 - TWO Way FRR - Timber Frame – 120 minute - Integra Lightweight Concrete Façade System with 2 layers of 16mm GIB Fyreline®



Framing to comply with

- NZBC B1 – Structure: AS1 Clause 3 – Timber (NZS 3604) or VM1 Clause 6 – Timber (NZS 3603)
- NZBC B2 – Durability: AS1 Clause 3.2 – Timber (NZS 3602)
- Studs at 600mm centres maximum
- Nogs at 1200mm centres for Horizontal fixing

Cladding to comply with

- NZBC Clause B1 Structure
- NZBC Clause B2 Durability
- NZBC Clause E2 External Moisture
- NZBC Clause F2 Hazardous Building Materials

Wall Heights

- Loadbearing – Framing dimensions and height as determined by NZS 3604 stud and top plate tables for loadbearing walls.

Linings

- 2 layers of 16mm GIB Fyreline® Plasterboard on the inside of the frame
- Vertical fixing only permitted. Sheets shall be touch fitted.
- Full height sheets shall be used where possible.
- When sheet end butt joints are unavoidable, they must be formed over solid framing and staggered from horizontal joints in the first layer.
- Joints of the outer layer are staggered from sheet end butt joints in the first layer.
- All sheet joints must be formed over solid timber framing.

Lining Fasteners

- INNER LAYER: 51mm x 7g GIB® Grabber® High Thread Drywall Screws.
- OUTER LAYER: 63mm x 8g GIB® Grabber® Self Tapping Screws

Lining Fastener Centres

- INNER LAYER: 600mm centres vertically up each stud 400mm centres horizontally along top and bottom plates.
- OUTER LAYER: 300mm centres on the sheet perimeter.
- Place fasteners 12mm from bound sheet edges and 18mm from sheet ends.
- Single screws at 300mm centres to intermediate studs.

Linings Jointing

- All fastener heads stopped and all sheet joints tape reinforced and stopped in accordance with the publication entitled "GIB® Site Guide".

Cladding

- 1 layer of 50mm Integra Lightweight Concrete Panel installed over a Timber Batten

Cladding Fastener Centres

- No closer than 50mm from the perimeter of the panel
- 3 screws per panel per stud
- Screws to be just below the surface of the panel

Cladding Mortar Joints

- Where panels join another panel or joints must use Rockcote MultiStop Bedding Compound to mortar the panels together.

Battens

- 20 mm minimum thickness – to give a 20 mm minimum width cavity
- 40 mm minimum width
- H3.1 treated
- SG6 grade radiata pine timber
- 75mm x 3.15mm hot-dip galvanised
- Fastened at 300mm centres

TradeSpec™ and RenderSpec™ are Registered Trademarks, both Documents are available on the Resene Construction Systems