

Sheet List Table	
Sheet Number	Sheet Title
78.00.00	Drawing Register
78.02.00	Foundation
78.03.00	External Corner
78.04.00	Internal Corner
78.05.00	Window Sill
78.06.00	Window Jamb
78.07.00	Window Head
78.08.00	Soffit
78.09.00	Roof Apron
78.10.00	Vertical Control Joint
78.11.00	Horizontal Control Joint
78.12.00	Meter Box Penetration

TradeSpec™ and RenderSpec™ are Registered Trademarks, both Documents are available on the Resene Construction Systems



CONFIDENTIALITY: No part of this publication may be reproduced or transmitted other than the intended use by Resene Construction Systems without written consent from the author.

System
Insulated Facade System


Substrate
EPS Panel 40mm (40mm Cavity)

Drawing Name
Drawing Register

Scale
1 : 2 @ A4

Date
21 June 2022

Sheet
78.00.00



Refer RCS
TradeSpec™ Document 1.2 for
information on Ground Clearances

TradeSpec™ and RenderSpec™ are Registered Trademarks, both Documents are available on the Resene Construction Systems

Resene 
Construction Systems

CONFIDENTIALITY: No part of this publication may be reproduced or transmitted other than the intended use by Resene Construction Systems without written consent from the author.

System
Insulated Facade System


Substrate
EPS Panel 75mm (20mm Cavity)

Drawing Name
Foundation

Scale
1 : 2 @ A4

Date
21 June 2022

Sheet
78.02.00



TradeSpec™ and RenderSpec™ are Registered Trademarks, both Documents are available on the Resene Construction Systems

Resene 
Construction Systems

CONFIDENTIALITY: No part of this publication may be reproduced or transmitted other than the intended use by Resene Construction Systems without written consent from the author.

System
 Insulated Facade System


Substrate
 EPS Panel 75mm (20mm Cavity)

Drawing Name
 External Corner

Scale
 1 : 2 @ A4

Date
 21 June 2022

Sheet
 78.03.00



Mesh to be wrapped continuously
around the internal corner, if there is
a break in the mesh then an additional
layer of Sticky Mesh must be used

TradeSpec™ and RenderSpec™ are Registered Trademarks, both Documents are available on the Resene Construction Systems

Resene 
Construction Systems

CONFIDENTIALITY: No part of this publication may be reproduced or transmitted other than the intended use by Resene Construction Systems without written consent from the author.

System
Insulated Facade System


Substrate
EPS Panel 75mm (20mm Cavity)

Drawing Name
Internal Corner

Scale
1 : 2 @ A4

Date
21 June 2022

Sheet
78.04.00



Allow a 25mm Gap between the back of the joinery and external facing timber framing to allow the sill flashing to fit.

TradeSpec™ and RenderSpec™ are Registered Trademarks, both Documents are available on the Resene Construction Systems

Resene 
Construction Systems

CONFIDENTIALITY: No part of this publication may be reproduced or transmitted other than the intended use by Resene Construction Systems without written consent from the author.

System
 Insulated Facade System


Substrate
 EPS Panel 75mm (20mm Cavity)

Drawing Name
 Window Sill

Scale
 1 : 2 @ A4

Date
 21 June 2022

Sheet
 78.05.00



Allow a 25mm Gap between the back of the joinery and external facing timber framing to allow the jamb flashing to fit.

TradeSpec™ and RenderSpec™ are Registered Trademarks, both Documents are available on the Resene Construction Systems

Resene 
Construction Systems

CONFIDENTIALITY: No part of this publication may be reproduced or transmitted other than the intended use by Resene Construction Systems without written consent from the author.


System
Insulated Facade System
 Substrate
EPS Panel 80mm (20mm Cavity)

Drawing Name
Window Jamb

Scale
1 : 2 @ A4

Date
21 June 2022

Sheet
78.06.00



RCS EdgeSealHead Flashing to extend past the aluminium window by 10mm

TradeSpec™ and RenderSpec™ are Registered Trademarks, both Documents are available on the Resene Construction Systems

Resene 
Construction Systems

CONFIDENTIALITY: No part of this publication may be reproduced or transmitted other than the intended use by Resene Construction Systems without written consent from the author.

System
 Insulated Facade System


Substrate
 EPS Panel 75mm (20mm Cavity)

Drawing Name
 Window Head

Scale
 1 : 2 @ A4

Date
 21 June 2022

Sheet
 78.07.00



TradeSpec™ and RenderSpec™ are Registered Trademarks, both Documents are available on the Resene Construction Systems

Resene 
Construction Systems

CONFIDENTIALITY: No part of this publication may be reproduced or transmitted other than the intended use by Resene Construction Systems without written consent from the author.

System
 Insulated Facade System


Substrate
 EPS Panel 80mm (20mm Cavity)

Drawing Name
 Soffit

Scale
 1 : 2 @ A4

Date
 21 June 2022

Sheet
 78.08.00



Refer RCS
TradeSpec™ Document 1.2 for
information on Roof Clearances

Metal flashing must be taped to the
Building Underlay by the main
contractor/window installer

TradeSpec™ and RenderSpec™ are Registered Trademarks, both Documents are available on the Resene Construction Systems

Resene 
Construction Systems

CONFIDENTIALITY: No part of this publication may be reproduced or transmitted other than the intended use by Resene Construction Systems without written consent from the author.

System
Insulated Facade System


Substrate
EPS Panel 75mm (20mm Cavity)

Drawing Name
Roof Apron

Scale
1 : 2 @ A4

Date
21 June 2022

Sheet
78.09.00



All Control Joint spacings and setouts are the responsibility of the Designer, for suggested locations refer to RCS TradeSpec™ Document 1.4

TradeSpec™ and RenderSpec™ are Registered Trademarks, both Documents are available on the Resene Construction Systems

Resene 
Construction Systems

CONFIDENTIALITY: No part of this publication may be reproduced or transmitted other than the intended use by Resene Construction Systems without written consent from the author.

System
 Insulated Facade System


Substrate
 EPS Panel 80mm (20mm Cavity)

Drawing Name
 Vertical Control Joint

Scale
 1 : 2 @ A4

Date
 21 June 2022

Sheet
 78.10.00



Please note that there should be no fixings into the floor joists, the substrate should be left floating over this point.

All Control Joint spacings and setouts are the responsibility of the Designer, for suggested locations refer to RCS TradeSpec™ Document 1.4 for suggested locations

Continuous cavities must not be limited to two-storeys or 7m in height in accordance with E2/AS1 Paragraph 9.1.9.4.

TradeSpec™ and RenderSpec™ are Registered Trademarks, both Documents are available on the Resene Construction Systems

Resene 
Construction Systems

CONFIDENTIALITY: No part of this publication may be reproduced or transmitted other than the intended use by Resene Construction Systems without written consent from the author.



System
 Insulated Facade System
 Substrate
 EPS Panel 75mm (20mm Cavity)

Drawing Name
 Horizontal Control Joint

Scale
 1 : 2 @ A4

Date
 21 June 2022

Sheet
 78.11.00



The responsibility for the penetration is the responsibility of the main contractor, where possible and practical use a flange.

TradeSpec™ and RenderSpec™ are Registered Trademarks, both Documents are available on the Resene Construction Systems

Resene 
Construction Systems

CONFIDENTIALITY: No part of this publication may be reproduced or transmitted other than the intended use by Resene Construction Systems without written consent from the author.

System
 Insulated Facade System
 Substrate
 EPS Panel 75mm (20mm Cavity)

Drawing Name
 Meter Box Penetration

Scale
 1 : 2 @ A4

Date
 21 June 2022

Sheet
 78.12.00